

## SAFV Renovation and Expansion Project

Addendum #2      7/2/2018

Item	Sheet/Spec	Comment
<b>GENERAL</b>		
1		Bid Opening Date is extended from July 9, 2:00 pm to July 16, 2:00 pm. All other details unchanged.
2		Mechanical addendum items are attached as separate 2-page PDF
<b>DRAWINGS</b>		
3	S402 (new)	Add: Attached new Detail 1/S402: illustrates wall/truss detail at lift
4	S402 (new)	Add: Attached new Detail 2/S402: illustrates wall/truss detail at lift
5	E001	Security Devices – Access Control Station: Add Key Fob
<b>SPECIFICATIONS</b>		
6	00-2113	Instructions to Bidders: 2.02 (A): Revise bid date to before 2:00 pm, July 16, 2018
7	28-1300	Access Control 2.5 Controllers 6. Control Power: Change backup Power-Supply Capacity to 6 hours.
8	28-2300	Video Surveillance 2.5 Power Supplies: Change Control Station module backup Power-Supply Capacity to 6 hours.

